

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:44 pm

PWS ID: UTAH23023 **Name:** DESERET CHEMICAL DEPOT
Legal Contact: DESERET CHEMICAL DEPOT **Rating:** Approved
D TROY JOHNSON **Rating Date:** 04/09/1996
Address: 11500 STARK RD **Activity Status:** Active
STOCKTON, UT 84071-9711
Phone Number: 435-833-4413
City Served (Area):
County: TOOELE COUNTY
System Type: Non Transient **Last Inv Update:** 07/18/2011 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 10/06/2009 **Total Dsgn Cap:**
Population: 1,436 **Surveyor:** VICKIE ROLFE **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers	Email Address
			Office	Emergency
AC	JOHNSON, D TROY		435-833-4198	

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Industrial	Unknown	0	85
			85 Total Svc Connections

Storage

Total Storage: 1,000,000 GAL **Number of Units:** 2 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST001	TANK #91	Ground	500,000 GAL	Concrete		A	
ST002	TANK #92	Ground	500,000 GAL	Concrete		A	

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	WELLS 1 AND 2 SOUTH CL2 ABANDONED		I	
TP002	NO 2 WELL SOUTH CHLORINATOR		A	

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	NO 1 WELL SOUTH# 5450	Active	WL	12	280 GPM	695 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS002	NO 2 WELL SOUTH # 5451	Active	WL	12	296 GPM	695 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS003	NO 3 WELLSOUTH ABANDC	Inactive	WL				Yes	GW	Other		

*Reports measured flow for wells, approved design capacity for all other sources.